INSTALLATION DECLARATION FOR GENERATING SETS
2 000 kW (2 500 kVA at PF=0.80)

Supplier : **MARGEN SpA**	Customer : **NOOVLE SpA**	Data Center : **S. STEFANO TICINO (MI)**
GENERATING SETS model	***GMU-2750 EWS***	***Serial numbers*** ***from 82870 to 82875***

GENERATING SETS RATINGS	UNIT	DECLARED VALUE	NOTE
Continuous Power, unlimited runtime at a constant load at the nameplate rating	kVA kW	**2500** **2000**	• Operating hours per year: unlimited • Load factor: ≤ 100% • Overload capability: 10% for 1h every 12h
The above declared Power Ratings are referred to the following ambient condition :			
extreme maximum dry bulb temperature	°C	**40.0**	
extreme minimum dry bulb temperature	°C	**- 15.8**	
relative humidity	RH %	**60**	
altitude above sea level	m	**234**	

The undersigned
Giovanni Gorzanelli, born in Modena (Italy) on 19/02/1968,
MANAGING DIRECTOR
of the company MARGEN S.p.A., registered office in Via Dino Ferrari 50, Maranello (Italy), VAT 02163220367,

DECLARES

that the installation proposed in design drawings of Noovle S. Stefano Ticino Data Center will not cause any Generators capacity derating in any wind condition.

MARGEN SpA
Managing Director

MARGEN S.p.A.

Firmato digitalmente da:
ROBERTO BACCINI
Noovle S.p.A.
Firmato il 26/08/2025 18:27
Seriale Certificato: 2346
Valido dal 23/07/2024 al 23/07/2027
TI Trust Technologies QTSP CA